

We Serve to Save

Prop.
G.H.BRAHMANKAR
(Fire Engineer / D.O.)
9960306589,7020803347
Lic No.:12GONP05105



G.B. ENTERPRISES

FIRE PROTECTION SYSTEM

Fire Protection Installation, Fire safety Equipments, Sales
& Service, Refilling of Fire Extinguisher, Maintenance etc.

E-mail : gbenterprises1954@gmail.com

At: Vidya Nagar (Ganesh Nagar) In front of Shiv Temple, Gondia (M.S.) 441001

FIRE SAFETY AUDIT REPORT

To,
The President / Secretary
Arushi Public School, Navegaon Bandh
Tah. Arjuni Mor. District : Gondia (M.S)

Date : 01/02/2025

Ref. : Circular No. MFS/51/2021/417, Dated 12/04/2021

Description of Building Premises

- 1) Building Height : 12 meters ; G + 2
- 2) Gat. No / Survey No. :
- 3) Type of Building : Educational
- 4) Name of Building :ARUSHI PUBLIC SCHOOL, NAVEGAONBANDH
(Tah. Arjuni/Mor.) District Gondia

This is to certify that, the fire protection system provided in the building were tested, checked and found functional at the time of Inspection.

Keeping in view the extent of compliance of the minimum standard on Fire Precaution and fire safety required under the rules, it is provided under provision of Maharashtra Fire Prevention and Life Safety measures act 2007 schedule 1. Amendment 2023; The Building is as per NBC Rules.

The Available Fire Fighting System at the Building are


- 1) Overhead water tank 5000 liters capacity
- 2) Fire Extinguisher ABC Type Dry chemical Powder 6 Kg + 4 Kg Capacity :10 Nos.
- 3) Stair Case available – 1 Nos. of 1.5 m width

The party has to provide Below said requirement at the site of Building.

- 1) Down Comer, connected with GI Pipe of 100 mm to the Terrace Overhead Tank of 10,000 Liter Capacity of RCC + Electric driven water pump of 450 LPM.
- 2) Hose Reel 20 mm dia. 30 m Length with shut off Nozzle – 3 Nos
- 3) Hose pipe 63/70 mm dia. 15 m length with SS coupling-6 Nos.
- 4) Hose Box Double – 3 Nos. of M.s. Sheet.
- 5) Fire Hydrant valve Single way of SS coupling 70 mm dia. – 3 Nos.
- 6) Fire Inlet Valve 2 way with SS coupling – 1 Nos.
- 7) Short Branch – 2 Nos.
- 8) Fire Alarm (M.C.P) – 3 Nos.
- 9) CO2 Fire Extinguisher of 4.5 kg – 1 Nos
- 10) Signage's
- 11) Fire Bucket 4 Nos. on Proper Stand.
- 12) Caution board : 3 Nos
- 13) Fire Alarm Bell – 1 Nos.

LIFE SAFETY : - AS PER N.B.C RULES Should be provided

- 1) External Stair shall have straight flight not less than 1250 mm wide from base to terrace of the building for the safe evacuation of pupils.
- 2) Gallery/passageway width should be upto 2.5 m.
- 3) Assembly place should be marked in front of the building at a safe distance from the building.



G. H. Brahmkar
Auditor/Consultant
Fire & Life Safety
Authorised by Director ..
M.F.S. Govt of M S Mumbai
Authorized Signature